

## **Academic Year 2022-23**

### **6.2**

## **Water Consumption Per Person**

- 6.2.1 Water consumption tracking**
- 6.2.2.1 Volume of Water used in University**
- 6.2.2.2 Campus Population**

**MRIIRS Weblink to SDG 6:**

<https://mriirs.edu.in/sdg06-clean-water-and-sanitation/>

### Water Consumption Tracking

Manav Rachna International Institute of Research and Studies (MRIIRS) is totally dependent on groundwater resource system of the area. MRIIRS has three tube wells located in various places in the campus and groundwater is extracted from these three tube wells (TWs) of the campus. All the wells are fitted with submersible pumps and water flow meters. These TWs are primary source of water for the campus with drawing groundwater from aquifer developed due to secondary porosity created by weathering and fracturing of quartzites of Delhi Supergroup. The water consumption is measured for entire campus as per well laid down SOP. A compilation of per day water extraction from TWs are appended. The average daily extraction is worked out **176 m<sup>3</sup>/day** from these data.

A register/log book is maintained by university **care taker** for each well to record daily readings of the meter fitted to each well. Monthly data of each well is reported to the **Supervisor**. The supervisor reports the compiled monthly data of all wells to the **Manager-maintenance** for data storage/record keeping in the university MIS. Supervisor also keeps track of maintenance of wells, meters and testing of water samples in regular interval.

As evidence in support to 6.2.1 photo graphs of tube wells with meter fitted to wells, water distribution plan along with total water consumption records, bills of repair/maintenance to wells and payment statements are available. All the data are available in public domain through web site of MRIIRS.


#### A. Geotagged Pictures of 3 Tube wells:

The details of three tube wells are as provided below:

1. Tubewell-1: Location- A Block
2. Tubewell-2: Location- Football ground
3. Tubewell-3: Location- Girls Hostel


The geotagged pictures of three tube wells are as provided on the next page:

# SDG 6- CLEAN WATER AND SANITATION



**Tubewell Specifications - A Block**

Latitude: 28.451209677767913, Longitude: 77.28392460048731  
28°27'04.4"N 77°17'02.1"E



**Tubewell - A Block**

Latitude: 28.45120985894735, Longitude: 77.2839296506137  
28°27'04.4"N 77°17'02.2"E

## Tubewell-1: Location- A Block



**Tubewell Specifications Football Ground**

Latitude: 28.45114881468702, Longitude: 77.2883329673434  
28°27'04.1"N 77°17'18.0"E



**Tubewell -Football Ground**


Latitude: 28.451188, Longitude: 77.288561  
28°27'04.0"N 77°17'18.0"E

## Tubewell-2: Location- Football ground



Tubewell Specifications - Girls Hostel

Latitude: 28.450961326595404 Longitude: 77.2890635129347  
28°27'03.5"N 77°17'20.6"E



Tubewell - Girls Hostel

Latitude: 28.45096437427463, Longitude: 77.28906995094304  
28°27'03.5"N 77°17'20.7"E

## Tubewell-3: Location- Girls Hostel

### B. Water Distribution Plan in MRIIRS and Total Water Consumption (Volume of Water Usage with respect to Campus Population)

All the three wells are fitted with submersible pumps and water flow meters. Tube wells water is first collected in 9 sumps having a capacity to store 660 m<sup>3</sup> of water located at various places. The water is then distributed to various blocks through well laid pipe network, where it is stored in 39 OHT (overhead tanks) having a capacity to store 131 m<sup>3</sup> each. The OHTs are of two types, one is for drinking water use and others are for other domestic use available in white and black colours to maintain the uniformity. The total quantity of raw water consumed in the campus is **176276 L/day**, which include 80% for domestic purposes and for other purposes like different laboratories, 20% for drinking supply. The total number of 7 R.O. systems have been installed in the campus at different blocks. The monthly inspection of R.O. system is carried out to check the quality of water. The leakage of the pipe line and joints, valves etc. is regularly checked by the civil and water works department to ensure proper working of the distribution system. Overhead and

## SDG 6- CLEAN WATER AND SANITATION



underground tanks are cleaned regularly throughout the year to maintain the supply of clean water. The records of total consumption of water in the MRIIRS campus are provided as below:

S. No.	Consumers	Total count	Water estimation in litres	
1	Professor	74	24	1776
2	Associate Professor	109	24	2616
3	Assistant Professor	235	24	5640
4	Non-Teaching	160	24	3840
5	Students- Undergraduate	3595	24	86280
6	Students- Post Graduate	595	24	14280
7	Students Ph.D	326	24	7824
8	Hostel	818	70	57260
9	Vendors	25	24	600
	<b>TOTAL</b>	<b>5937</b>	<b>TOTAL</b>	<b>176276</b>

Total quantity of raw water consumed in the campus is **176276 L/day** with a **total campus population of 5937**.


The total population of the campus is 5937 for year 2022 including students, faculty members, non-teaching staff, quarters in campus and vendors having stores in campus. The average daily per capita consumption has been worked out to be **29.69 litres per day** on the basis of collected data.

The detailed water distribution plan of the campus with marked locations is as presented as **Annexure I** followed by Ground Water Flow Pattern of MRIIRS.

# SDG 6- CLEAN WATER AND SANITATION




## Annexure I



**Water Distribution Plan: MRIIRS Campus**

**MANAV RACHNA INTERNATIONAL INSTITUTE OF RESEACH AND STUDIES, FARIDABAD**

## SDG 6- CLEAN WATER AND SANITATION



**Ground Water Flow Pattern of MRIIRS Campus**


# **Annexure I**

## **Detailed water distribution plan of the campus**





## WATER MANAGEMENT AT MRIIRS CAMPUS AT A GLANCE



- ★ Ground Water Recharge Structure
- Rain Water Harvesting
- ◆ Solid Waste Management
- ◆ Solar Power Unit
- ▲ STP
- ◆ RO-Plant
- Tube Well
- Water Storage

**Centre for Advance Water Technology & Management**

### C. Tube wells Maintenance:

Tube wells are also checked periodically throughout the year to ensure the proper supply of raw water. It includes maintenance of submersible pumps, fittings and fixtures, motor winding, replacement of broken pipes, installation of new cables etc. The records of the same are attached as follows:

- ✓ Invoices of purchase of various parts of the borewells and maintenance of borewells: **Annexure IIa**,
- ✓ Invoices of cleaning and chemical treatment of underground and overhead tanks: **Annexure IIb** and
- ✓ Water testing certificate: **Annexure-IIc**.

## **Annexure II a**

**Invoices of purchase of various parts of the borewells and maintenance of borewells**

TIN : 06ACXPS3493C1Z3

**GST - INVOICE**

State : Haryana  
State Code : 06

**TUBE WELL ENGG. WORKS**

INVOICE No. : 2200

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

Date 04-01-2023

To, **MRIIRS**  
M/s.

Sector - 43  
Faridabad

Order No. 2022-23/JUNE/MRIIRS/GA/NO/047

Date 10/12/2022 H.P. 7.5 Stages Monoblock

Party's GSTIN No. 06AADTM7279E12D

Our Challan No. 15083 Dt. 18/11/2022


State Haryana State Code 06

RMGP 266 Date 15-10-2022

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.	P.
1	Motor Winding kit	8544	1 no ✓	3800/- ✓	3800=00 ✓	
2	Bearing 6305 22	8413	1 no ✓	430/- ✓	430=00 ✓	
3	Bearing 6306 22	8413	1 no ✓	520/- ✓	520=00 ✓	
4	Neckring Gm	8413	2 nos. ✓	90/- ✓	180=00 ✓	
5	Rotor Repairing	9987	1 Job ✓	300/- ✓	300=00 ✓	
6	Labour Charges for motor	9987	1 Job ✓	500/- ✓	500=00 ✓	
					5730=00	
TOTAL					5730=00	
CGST@9%					516=00	
SGST@9%					516=00	
IGST@1%					1	
GRAND TOTAL					6762=00	

Total Invoice Value (in words) Rs. Six thousand seven hundred sixty two only.

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign.  Auth. Signatory  
For TUBE WELL ENGG. WORKS

GSTIN : 06ACXPS3493C1Z3

GST - INVOICE

State : Haryana  
State Code : 06

# TUBE WELL ENGG. WORKS

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

INVOICE No. : 2205

Date ...06/01/2023...

To, M/s. **MRIIRS**  
Sector - 43  
Faridabad.  
Party's GSTIN No. **06AADTM7279E12D**  
State **Haryana** State Code **06**

Order No. **2022-23/DUNE/MRIIRSKSA/wd/046**  
Date **10/12/2022** H.P. **5** Stages **HSM P**  
Our Challan No. ....Dt. ....  
RMGP.....Date.....

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.
1	Motor Winding kit	8544	1 no ✓	2100/-	2100/-
2	Bearing Bush GM	8413	4 nos ✓	180/-	720/-
3	Water Seal	8413	2 nos ✓	25/-	50/-
4	Cable Seal	8413	1 no ✓	20/-	20/-
5	Rotor Repairing	9987	1 Job ✓	325/-	325/-
6	Thrust Bearing Pad	8413	2 nos ✓	870/-	1740/-
7	Thrust Plate	8413	1 no ✓	500/-	500/-
8	Neckling GM	8413	1 no ✓	180/-	180/-
9	Impeller Repairing	9987	1 Job ✓	150/-	150/-
10	Labour charges for motor	9987	1 Job ✓	300/-	300/-
					6085/-


OK  
Alys  
B.V. Vijay  
Rs. 7181/-  
12/01/23

TOTAL	6085/-
CGST@.....9.....%	548/-
SGST@.....9.....%	548/-
IGST@...../.....%	

Total Invoice Value (in words) Rs. **Seven thousand one hundred eighty one only.**

GRAND TOTAL **7181/-**

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign.  Auth. Signatory  
For TUBE WELL ENGG. WORKS

TIN : 06ACXPS3493C1Z3

GST - INVOICE

State : Haryana  
State Code : 06

**TW Tube Well Engg. Works**

INVOICE No. : 2204

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

Date 06/01/2023

To, **MRIIRS**  
M/s. Sector-43  
Faridabad.  
Party's GSTIN No. 06AADTM7279E12D  
State Haryana State Code 06

Order No 2022-23/JUNE/MRIIRS/GA/WO/048  
Date 10/12/2022 H.P. 1.5 Stages Monoblock  
Our Challan No. ....Dt. ....  
RMGP 263 Date 1-10-2022

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.	hp.
①	Motor Winding kit	8544	1 no	1500/-	1500	hp
②	labour charges for motor	9987	1 job	350/-	350	
					1850	
TOTAL					1850	
CGST@.....9.....%					166	
SGST@.....9.....%					166	
IGST@.....1.....%					1	

Total Invoice Value (in words) Rs. Two thousand one hundred eighty three only

GRAND TOTAL 2183

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign. [Signature]  
For TUBE WELL ENGG. WORKS  
Auth. Signatory

STIN : 06ACXPS3493C1Z3

GST - INVOICE

State : Haryana  
State Code : 06

**TUBE WELL ENGG. WORKS**

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

INVOICE No. : 2198

Date : 03-01-2023


To, M/s. **MRIIRS**  
Sector - 43  
Faridabad  
Party's GSTIN No. **06AADTM7279E12D**  
State **Haryana** State Code **06**

Order No **2022-23/JUNE/MRIIRS/GA/WO/049**  
Date **10/12/2022** H.P. **2** Stages **15**  
Our Challan No. **15080** Dt. **17-11-2022**  
RMGP **465** Date **09-09-2022**

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.
①	Bush Housing machining	8413	4 nos ✓	175/- ✓	700/- ✓
②	Bearing Bush 6m	8413	4 nos ✓	140/- ✓	560/- ✓
③	Water Seal	8413	2 nos ✓	20/- ✓	40/- ✓
④	Cable Seal	8413	1 no ✓	20/- ✓	20/- ✓
⑤	Motor Repairing	9987	1 job ✓	300/- ✓	300/- ✓
⑥	Thrusting Bearing Block	8413	1 no ✓	420/- ✓	420/- ✓
⑦	Thrust plate	8413	1 no ✓	200/- ✓	200/- ✓
⑧	Coupling S.S.	8413	1 no ✓	165/- ✓	165/- ✓
⑨	Pump shaft S.S.	8413	1 no ✓	400/- ✓	400/- ✓
⑩	Impeller Nonyal	8413	15 nos ✓	65/- ✓	975/- ✓
⑪	Stage Bowl Nonyal	8413	15 nos ✓	65/- ✓	975/- ✓
⑫	Inlet piece Nonyal	8413	1 no ✓	70/- ✓	70/- ✓
⑬	Thrusting Adjusting Bush & washers	8413	1 no ✓	85/- ✓	85/- ✓
⑭	Labour charges for motor Pump	9987	1 job ✓	750/- ✓	750/- ✓
					5660/- ✓
TOTAL					5660/- ✓
CGST@ 9%					509/- ✓
SGST@ 9%					509/- ✓
IGST@ 1%					✓
GRAND TOTAL					6678/- ✓

Total Invoice Value (in words) Rs. **Six thousand and hundred seventy eight only**

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign.  Auth. Signatory  
For TUBE WELL ENGG. WORKS

GSTIN : 06ACXPS3493C1Z3

**GST - INVOICE**

State : Haryana  
State Code : 06

**TUBE WELL ENGG. WORKS**

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

INVOICE No. : **2135**

Date 16/09/22

To, M/s. Manan Roshni International Ins. Co. Ltd.  
Research & Dev.

Order No. 2022/23/Dep/MR/HS/GAP/WO/40

Date 14-9-22 H.P. .... Stages .....

Party's GSTIN No. 06AADTM7279E120

Our Challan No. 15028 dt 14-9-22

State Haryana State Code 06

RMGP 850 Date 14-9-22

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.	P.
1.	Motor winding	8544	1 NO	9500	9500	
2.	Labour charges for motor	9987	1 NO	1000	1000	
					<u>10500</u>	
TOTAL					<u>10500</u>	
					CGST@ <u>9</u> %	<u>945</u>
					SGST@ <u>9</u> %	<u>945</u>
					IGST@ <u>—</u> %	<u>—</u>
GRAND TOTAL					<u>12390</u>	

*Bill ✓ filed for  
Rs 12390*

Total Invoice Value (in words) Rs. Twelve thousand three hundred ninety only

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign.

For TUBE WELL ENGG. WORKS  
*[Signature]*  
Auth. Signatory



N : 06ACXPS3493C1Z3

GST - INVOICE

Lowery 14-9-22

State : Haryana  
State Code : 06

# TUBE WELL ENGG. WORKS

INVOICE No. : 2178

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

Date 24-11-2022

To, M/s. MR.II.R.S.

Order No. ....

Sector - 43  
Faridabad

Date.....H.P.....Stages.....

Party's GSTIN No. 06AADTM7279E1ZD

Our Challan No. ....Dt. ....

State Haryana State Code 06

RMGP.....Date.....

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.	P.
①	Dismantling / Lifting & Reinstallation of Submersible Motor Pump upto 900'	9987	1 Job	3150/-	31500=0	
②	Cartage charges for try try pit and other equipment and accessories etc. as reqd.	9987	1 Job	390/-	390=0	
					3540=0	
Billed monthly on dt- 9-9-2022 and installation on dt 14-9-2022						
TOTAL					3540=0	
CGST@.....9.....%					319=0	
SGST@.....9.....%					319=0	
IGST@.....1.....%					/	
GRAND TOTAL					4178=0	

Total Invoice Value (in words) Rs. Four thousand one hundred seventy eight only

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign. For TUBE WELL ENGG. WORKS  
Auth. Signatory

# TUBE WELL ENGG. WORKS

INVOICE No. : 2179

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

Date 28-11-2022

To, M/s. MR IIRS  
Sector 43 Faridabad  
Party's GSTIN No. 06AADTM7279E1ZD  
State Haryana State Code 06


Order No 28-23/SP/MRIRS/GA/40  
Date 18-11-22 H.P. 20 Stages  
Our Challan No. 15087 Dt. 28-11-2022  
RMGP 255 Date 16/09/2022

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.	P.
1	Motor winding kit 20 HP	8544	1 No	9500/-	9500	Rs
2	Labour charge for motor		1 No	1000/-	1000	Rs
					10500	Rs
TOTAL					10500	Rs
CGST@9%					945	Rs
SGST@9%					945	Rs
IGST@%					/	
GRAND TOTAL					12390	Rs

Total Invoice Value (in words) Rs. Twelve Thousand Three hundred & Ninety only

E. & O. E. Terms & Conditions :  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign.

For TUBE WELL ENGG. WORKS  
  
Auth. Signatory

N : 06ACXPS3493C1Z3

**GST - INVOICE**

State : Haryana  
State Code : 06

**TUBE WELL ENGG. WORKS**

SALES, SERVICE, REWINDING & REPAIRING OF SUBMERSIBLE, PUMP SETS  
DRILLING & DEVELOPMENT OF TUBEWELL BY RIG MACHINE & AIR COMPRESSOR  
F.C.A.-3153, Gali No. 4, Block-A, S.G.M. Nagar, N.I.T. Faridabad-121001  
Mob. : 9212556962, 9911556961 ; E-mail : tubewellengg@yahoo.in

INVOICE No. : 2175

Date : 22-11-2022


To, M/s. **MR. I. R. S.**  
Sector-43  
Faridabad  
Party's GSTIN No. **06AADTM7279E12D**  
State: **Haryana** State Code: **06**

Order No. ....  
Date.....H.P.....Stages.....  
Our Challan No. ....Dt. ....  
RMGP.....Date.....

S. No.	DESCRIPTION OF GOODS	HSN/SAC CODE	QTY.	RATE	AMOUNT Rs.	P.
①	Dismantling Lifting & Reinstallation of Submersible motor pump up to 200 feet (1 1/2" x 150' length)	9987	1 Job	3150/-	3150=0	
②	Cartage charges of Try Rod Stand and other equipment and accessories etc as reqd.	9987	1 Job	390/-	390=0	
	Dismantling and Installation (Chowerry) on dt- 7-11-2022.				3540=0	
<b>TOTAL</b>					<b>3540=0</b>	
					CGST@.....9.....%	319=0
					SGST@.....9.....%	319=0
					IGST@.....1.....%	1
<b>GRAND TOTAL</b>					<b>4178=0</b>	

Total Invoice Value (in words) Rs. **Four thousand one hundred eighty eight only.**

**E. & O. E. Terms & Conditions :**  
1. Interest @ 20% p.a. will be charged if the payment is not made with due dates  
2. All disputes are subject to Faridabad jurisdiction

Receiver's Sign.  **For TUBE WELL ENGG. WORKS**  
Auth. Signatory

## **Annexure II b**

### **Invoices of cleaning and chemical treatment of underground and overhead tanks**

No. 06BBQPS9007M2ZV

TAX INVOICE

M: 9810474087

# GANGOTRI PURIFIERS

Regd. Office : Plot No. 403, Gate No. 3, Sector-46, Faridabad - 121001 (Hr.)

- Original for Buyer
- Duplicate for Transporter
- Triplicate for Assessee

Invoice Serial No. : **241** Invoice Date : **31/10/22** Transportation Mode : .....  
 State : Haryana, State Code : 06 Veh. No. ....  
 Reverse Charge : (Yes/No) Date & Time of Supply : .....  
 Place of Supply : ..... Party P.O. ....

**Detail of Receiver / Consignee**  
 Name **MRIIRS**  
 Address **Surya Kund Road, Sec-43, FBD.**  
 GSTIN **06AADTM729E1ZD** State **HR** State Code **06**

S. No.	Description of Goods	HSN Code (GST)	Qty	Rate As per Item	Unit	Taxable Value	
						Rs.	P
1)	Cleaning and Chemical Treatment of underground and of water storage tanks -	999 412	-	18,620/-	-	18,620	00

*Handwritten notes:*  
 Bill verified  
 Rs. 21972/-  
 15/11/22

Invoice Value (in word) **Rupees twenty one thousand nine hundred seventy one and paise sixty only -**

Total	18,620-00
Freight Charges	-
CGST.....9.....%	1675-80
SGST.....9.....%	1675-80
IGST.....%	-
Round Off	2,971-60
Invoice Total	21,971-60

Certified that the particulars given above are true and correct and the amount indicated represents the price actually charged and that there is no flow of additional consideration directly or indirectly from the buyer.

**Term & Conditions:**  
 1. Please pay by Payment A/C Cheque / DD only. 2. All disputes subject to Faridabad jurisdiction Only.  
 3. If payment is not made within 15 days interest @ 24% per annum will be charged.

E & O.E.  
 Received the above goods in good conditions :  
 Customer's Signature \_\_\_\_\_ Checked by \_\_\_\_\_  
 For Gangotri Purifiers \_\_\_\_\_  
 Authorised Signatory \_\_\_\_\_

IN No. 06BBQPS9007M2ZV

TAX INVOICE

M: 9810474087

# GANGOTRI PURIFIERS

Regd. Office : Plot No. 403, Gate No. 3, Sector-46, Faridabad - 121001 (Hr.)

- Original for Buyer
- Duplicate for Transporter
- Triplicate for Assessee

Invoice Serial No. : **249**      Invoice Date : **16/12/22**      Transportation Mode : .....

State : Haryana,      State Code : 06      Veh. No. ....

Reverse Charge : (Yes/No)      Date & Time of Supply : .....

Place of Supply : ..... Party P.O. ....

**Detail of Receiver / Consignee**

Name ..... **MRIIRS** .....

Address ..... **Sec-43, Surajkund Road** .....

..... **Faridabad** .....

GSTIN .....      State **HR** .....      State Code **06** .....

S. No.	Description of Goods	HSN Code (GST)	Qty	Rate As per Item	Unit	Taxable Value	
						Rs.	P
1)	<b>Cleaning and chemical treatment of underground and open water storage tanks —</b>	<b>999 412</b>	—	—	—	<b>35,401</b>	<b>76</b>
<p><i>List of tank details attached</i></p> <p><i>Bill verified per Ms. 21774/2022</i></p> <p><i>21/12/22</i></p>							

Invoice Value (in word) <b>Forty one thousand seven hundred seventy four and paise eight only</b>	Total	<b>35,401</b>	<b>76</b>
	Freight Charges	—	—
	CGST.....9%	<b>3,186</b>	<b>16</b>
	SGST.....9%	<b>3,186</b>	<b>16</b>
	IGST.....%	—	—
	Round Off	<b>41,774</b>	<b>08</b>
	Invoice Total	<b>41,774</b>	<b>08</b>

Certified that the particulars given above are true and correct and the amount indicated represents the price actually charged and that there is no flow of additional consideration directly or indirectly from the buyer.

**Term & Conditions:**  
 1. Please pay by Payment A/C Cheque / DD only.      2. All disputes subject to Faridabad jurisdiction Only.  
 3. If payment is not made within 15 days Intrest @ 24% per annum will charged.

E & O.E.  
 Received the above goods in good conditions :  
 Customer's Signature      Checked by      For Gangotri Purifiers      Authorised Signatory

No. 06BBQPS9007M2ZV

TAX INVOICE

M: 9810474087

# GANGOTRI PURIFIERS

Regd. Office : Plot No. 403, Gate No. 3, Sector-46, Faridabad - 121001 (Hr.)

- Original for Buyer
- Duplicate for Transporter
- Triplicate for Assessee

Invoice Serial No. : <b>252</b>	Invoice Date : <u>16/12/22</u>	Transportation Mode : .....
State : Haryana,	State Code : 06	Veh. No. ....
Reverse Charge : (Yes/No)		Date & Time of Supply : .....
		Place of Supply : ..... Party P.O. ....

**Detail of Receiver / Consignee**

Name : MR IIRS

Address : Sec-43, Seekaj Kund Road

GSTIN : ..... State : ..... State Code : .....

S. No.	Description of Goods	HSN Code (GST)	Qty	Rate As per Item	Unit	Taxable Value	
						Rs.	P
1)	cleaning and chemical treatment of underground and of water storage tanks — at-721 A, EC-21A	999 412	2	500.00	-	1000	00
1)	5 KL of water tank						
2)	2 KL " "		1	350.00	-	350	00
3)	Underground tank (1.522X 2.487X 2.335) mts			40		353	
				900.00	-	900	00
<b>Total</b>						1703	

Invoice Value (in word) : Rupees two thousand six hundred  
fifty five only —

Freight Charges	153.27	-
CGST.....9%	202	50
SGST.....9%	202	50

Certified that the particulars given above are true and correct and the amount indicated represents the price actually charged and that there is no flow of additional consideration directly or indirectly from the buyer.

20/12/22

IGST.....%	202	50
Round Off	2655	00
<b>Invoice Total</b>	<b>2655</b>	<b>00</b>

**Term & Conditions:**

1. Please pay by Payment A/C Cheque / DD only.
2. All disputes subject to Faridabad jurisdiction Only.
3. If payment is not made within 15 days interest @ 24% per annum will charged.

E & O.E.  
Received the above goods in good conditions :

Customer's Signature \_\_\_\_\_ Checked by \_\_\_\_\_ For Gangotri Purifiers \_\_\_\_\_  
Authorized Signatory \_\_\_\_\_

N : 06BBQPS9007M2ZV

Tax Invoice

Mob. : 9810474087

# GANGOTRI PURIFIERS

Regd. Office : Plot No. 403, Gali No. 3, Sector-46, Faridabad-121001 (Hr.)

Original for Buyer  
Duplicate for Transporter  
Triplicate for Assessee

State : Haryana  
State Code : 06

Invoice Serial No. : **253**

Transportation Mode : .....

State : Haryana

Invoice Date : 17/04/23

Veh. No. : .....

Reverse Charge : (Yes / No.) State Code : 06

Date of Time of Supply : .....

Place of Supply : ..... Party P.O.....

Name PURIFIERS (Mount View Apartment - Sec-45)  
Surya Kund Road, Sec - 43, FRO.

GSTIN 06AADTM7279E1D State HR State Code 06

S. No.	Description of Goods	HSN/SAC Code	Qty.	Unit	Rate As per Item	Taxable Amount Rs. P.
1)	Cleaning of water tanks -	999			0.04	
i)	Underground tanks	412	1 Lac	-	40.00	4,000.00
ii)	Overhead RCC tanks		1 No	(25KL)	1500.00	1,500.00
iii)	Overhead PVE tanks		9	-	350.00	3,150.00
iv)	" " PVC 1KL				250.00	250.00

OK checked  
prelata

Bill verified  
Rs. 10502/- only  
19/4/23

Rupees in words Ten thousand five hundred two only Total 8902.00

Certified that the particulars given above are true and correct and the amount indicated represents the price actually charged and that there is no flow of additional consideration directly or indirectly from the buyer.

CGST.....9...%	801.80
SGST.....9...%	809.40
IGST.....%	-
Round Off	10,502.00
Invoice Total	10,502.00

E. & O.E.  
Received the above goods in good Conditions.

For Gangotri Purifiers  
Authorized Signatory

Customer's Signature

Checked by



## **Annexure II c**

# **Water Testing Certificates**



A Block

SWTD/F/GEN/05(REV.02)

# STAR WIRE (INDIA) LTD. (TESTING DIVISION)

21/4, MATHURA ROAD, BALLABGARH-121 004 (HR.)  
TELEPHONE : 0129-4094247, 4094200  
4094280, 2241263  
E-MAIL : swdc06@starwire.in  
VISIT US AT : www.starwire.in

## TEST REPORT

No. 019069

Issue Date : 17.06.2023

Issued To : MANAV RACHNA INTERNATIONAL INSTITUTE OF  
RESEARCH AND STUDIES  
SECTOR-43, ARRAVLI HILLS, DELHI  
SURAJ KUND ROAD, FARIDABAD (HR)  
Sample Particulars :

Request No./Date : NIL  
Date of sample Receipt : 07.06.2023  
Sample drawn by : 07.06.2023  
CUSTOMER  
Job order no. : 43441301

SAMPLE OF RO WATER (DRINKING PURPOSE)

ULR NO. :

CHEMICAL TESTING	:	WATER
DATE OF TESTING	:	07.06.2023 TO 13.06.2023

S.NO.	TEST PARAMETER	UNIT	RESULTS	SPEC. (Max.) AS PER IS:10500 -2012		PROTOCOL, REF. TO PART OF IS 3025
				Acceptable	Permissible	
<b>C</b>	<b>Toxic substances Tests</b>					
1	Taste	--	Agreeable	Agreeable	Agreeable	Part-7 & 8-1984(RA:2017)
<b>D</b>	<b>Bacteriological Tests</b>					
2	Total Coliform Bacteria	MPN / 100 ml	N.D.	Not detectable / 100 ml		IS: 1622--1981(RA:2019)
3	E. Coli	MPN / 100 ml	N.D.	Not detectable / 100 ml		IS: 1622--1981(RA:2019)

Remarks:- The sample conforms to IS:10500 – 2012 (Acceptable) w.r.t. above test parameters only

Note:- It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under 'Permissible limit' in the absence of alternate source in the 'permissible limits' above which the sources will have to be rejected.  
Conformation limit for chlorine is applicable when water is chlorinated.

\*\* END OF REPORT \*\*

AUTHORISED SIGNATORY



- Note
1. Sample will be retained only for one month. (15 days in case of water and air samples).
  2. The results listed refer only to the tested sample and applicable parameters. Endorsement of product is neither inferred nor implied.
  3. Total liability of our works is limited to invoiced amount.
  4. This report can not used as an evidence in a court of law without the written approval of the lab.
  5. Report shall not be reproduced except in full, without the written approval of the laboratory.
  6. Any sort of play by the customer with the data of this report shall be illegal.
- Contact No. : 8376908276, 8376908204, 9313511396, 8376900334, 8376900330



A Block

SWTD/F/GEN/05(REV.02)

# STAR WIRE (INDIA) LTD. (TESTING DIVISION)

## TEST REPORT

No. **082456**

Issue Date : 17.06.2023

Issued To : **MANAV RACHNA INTERNATIONAL INSTITUTE OF RESEARCH AND STUDIES  
SECTOR-43, ARRAVLI HILLS, DELHI  
SURAJ KUND ROAD, FARIDABAD (HR)**

Sample Particulars :

SAMPLE OF RO WATER (DRINKING PURPOSE)

21/4, MATHURA ROAD, BALLABGARH-121 004 (HR.)  
TELEPHONE : 0129-4094247, 4094200  
4094280, 2241263

E-MAIL : swdc06@starwire.in  
VISIT US AT : www.starwire.in

Request No./Date : NIL

Date of sample Receipt : 07.06.2023

Sample drawn by : 07.06.2023

Job order no. : CUSTOMER

ULR NO. : 43441301

ULR NO. : TC516423000011581F

CHEMICAL TESTING	:	WATER
DATE OF TESTING	:	07.06.2023 TO 13.06.2023

Sl.No.	Test Parameter	Units	Results	Spec. (Max.) As Per IS:10500 -2012		Protocol, Ref. to part of IS 3025
				Acceptable	Permissible	
<b>A</b>	<b>Organoleptic &amp; Physical Tests</b>					
1	Colour	Hazen	<5.0	5	15	Part - 4-2021
2	Odour	N.A	Agreeable	Agreeable	Agreeable	Part -5-2018
3	pH Value at 25°C	N.A	6.75	6.5 - 8.5	No Relaxation	Part - 11-2022
4	Turbidity	NTU	<1.0	1	5	Part - 10-1984(RA:2022)
5	Total Dissolved Solids at 105°C	mg/l	146.0	500	2000	Part - 16-1984(RA:2022)
<b>B</b>	<b>General Test Parameters</b>					
6	Chloride as Cl	mg/l	26.0	250	1000	Part - 32-1988(RA:2019)
7	Fluoride as F	mg/l	0.08	1	1.5	APHA 4500 F 4-82:2012
8	Iron as Fe	mg/l	<0.05	0.3	No Relaxation	Part - 53-2003(RA:2019)
9	Total Hardness as CaCO <sub>3</sub>	mg/l	49.0	200	600	Part - 21-2009(RA:2019)

Remarks:- The sample conforms to IS:10500 - 2012 w.r.t. (Acceptable) above test parameters only.

Note:- It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under 'Permissible limit' in the absence of alternate source in the permissible limits' above which the sources will have to be rejected.

•• END OF REPORT ••

  
**AUTHORISED SIGNATORY**

- Note**
1. Sample will be retained only for one month. (15 days in case of water and air samples).
  2. The results listed refer only to the tested sample and applicable parameters. Endorsement of product is neither inferred nor implied.
  3. Total liability of our works is limited to invoiced amount.
  4. This report can not used as an evidence in a court of law without the written approval of the lab.
  5. Report shall not be reproduced except in full, without the written approval of the laboratory.
  6. Any sort of play by the customer with the data of this report shall be illegal.

Contact No. : 8376908276, 8376908204, 9313511396, 8376900334, 8376900330

# STAR WIRE (INDIA) LTD.

## (TESTING DIVISION)

21/4, MATHURA ROAD, BALLABGARH-121 004 (HR.)  
 TELEPHONE : 0129-4094247, 4094200  
 4094280, 2241263  
 E-MAIL : swdc06@starwire.in  
 VISIT US AT : www.starwire.in

### TEST REPORT

**No.078173**

Issue Date : 24.04.2023

Issued To : MANAV RACHNA INTERNATIONAL INSTITUTE OF RESEARCH AND STUDIES  
 SECTOR-43, ARRAVLI HILLS, DELHI  
 SURAJ KUND ROAD, FARIDABAD (HR)

Sample Particulars :

SAMPLE OF RO WATER (DRINKING PURPOSE)

*H Black*

Request No./Date : NIL  
 Date of sample Receipt : 15.04.2023  
 15.04.2023  
 Sample drawn by : CUSTOMER  
 Job order no. : 43339803  
 ULR NO. : TC516423000007686F

CHEMICAL TESTING	:	WATER
DATE OF TESTING	:	15.04.2023 TO 21.04.2023

Sl.No.	Test Parameter	Units	Results	Spec. (Max.) As Per IS:10500 -2012		Protocol, Ref. to part of IS 3025
				Acceptable	Permissible	
<b>A Organoleptic &amp; Physical Tests</b>						
1	Colour	Hazen	<5.0	5	15	Part - 4-2021
2	Odour	N.A	Agreeable	Agreeable	Agreeable	Part -5-2018
3	pH Value at 25°C	N.A	6.79	6.5 - 8.5	No Relaxation	Part - 11-2022
4	Turbidity	NTU	<1.0	1	5	Part - 10-1984(RA:2022)
5	Total Dissolved Solids at 105°C	mg/l	138.0	500	2000	Part - 16-1984(RA:2022)
<b>B General Test Parameters</b>						
6	Chloride as Cl	mg/l	22.0	250	1000	Part - 32-1988(RA:2019)
7	Fluoride as F	mg/l	0.07	1	1.5	APHA 4500 F 4-82:2012
8	Iron as Fe	mg/l	<0.05	0.3	No Relaxation	Part - 53-2003(RA:2019)
9	Total Hardness as CaCO <sub>3</sub>	mg/l	49.0	200	600	Part - 21-2009(RA:2019)

Remarks:- The sample conforms to IS:10500 - 2012 w.r.t. (Acceptable) above test parameters only.

Note:- It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under 'Permissible limit' in the absence of alternate source in the permissible limits' above which the sources will have to be rejected.

•• END OF REPORT ••



AUTHORISED SIGNATORY



# TEST REPORT

No. **018343**

Issue Date : 24.04.2023

Issued To : MANAV RACHNA INTERNATIONAL INSTITUTE OF RESEARCH AND STUDIES  
SECTOR-43, ARRAVLI HILLS, DELHI  
SURAJ KUND ROAD, FARIDABAD (HR)

Sample Particulars :

SAMPLE OF RO WATER (DRINKING PURPOSE)

H Block

## STAR WIRE (INDIA) LTD. (TESTING DIVISION)

21/4, MATHURA ROAD, BALLABGARH-121 004 (HR.)

TELEPHONE : 0129-4094247, 4094200  
4094280, 2241263

E-MAIL : swdc06@starwire.in  
VISIT US AT : www.starwire.in

Request No./Date : NIL

Date of sample Receipt : 15.04.2023  
15.04.2023

Sample drawn by : CUSTOMER

Job order no. : 43339803

ULR NO. : TC5164230000076

CHEMICAL TESTING	:	WATER
DATE OF TESTING	:	15.04.2023 TO 21.04.2023

S.NO.	TEST PARAMETER	UNIT	RESULTS	SPEC. (Max.) AS PER IS:10500 -2012		PROTOCOL, REF. TO PART OF IS 3025
				Acceptable	Permissible	
<b>C</b>	<b>Toxic substances Tests</b>					
1	Taste	--	Agreeable	Agreeable	Agreeable	Part-7 & 8-1984(RA:2017)
<b>D</b>	<b>Bacteriological Tests</b>					
2	Total Coliform Bacteria	MPN / 100 ml	N.D.	Not detectable / 100 ml		IS: 1622--1981(RA:2019)
3	E. Coli	MPN / 100 ml	N.D	Not detectable / 100 ml		IS: 1622--1981(RA:2019)
Remarks:- The sample conforms to IS:10500 – 2012 (Acceptable) w.r.t. above test parameters only						
Note:- It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under 'Permissible limit' in the absence of alternate source in the 'permissible limits' above which the sources will have to be rejected. Conformation limit for chlorine is applicable when water is chlorinated.						

\*\* END OF REPORT \*\*



AUTHORISED SIGNATORY

- Note
- Sample will be retained only for one month. (15 days in case of water and air samples).
  - The results listed refer only to the tested sample and applicable parameters. Endorsement of product is neither inferred nor implied.
  - Total liability of our works is limited to invoiced amount.
  - This report can not used as an evidence in a court of law without the written approval of the lab.
  - Report shall not be reproduced except in full, without the written approval of the laboratory.
  - Any sort of play by the customer with the data of this report shall be illegal.
- Contact No. : 8376908276, 8376908204, 9313511396, 8376900334, 8376900330

JAS-ANZ


**i Indus Cosmeceuticals Pvt. Ltd.**
**Formerly FDRA Labs India Pvt. Ltd.**

 ISO 9001 : 2008 (QMS) Certified  
 Estd. Since 1976

 Regd. Office : 819, Sector-7C, Faridabad.  
 CIN : U74999HR1996PTC033021  
 GSTIN No. 06AAACF2001M1Z3  
 Office : HSIIDC No. 138-139,  
 Sector-31, Faridabad-121 003 (India)  
 Phone : 91-129-2278584, 2279087  
 E-mail : fdralabs@incosmetics.org

Ref.No.:FDRA/21165/2022

Dated:19/12/2022

## TEST CERTIFICATE

Date &amp; Time of Collection:- N.A.

Date of Receipt:17/12/2022

Collected by:- Sender

Date of Analysis:17/12/2022 to 19/12/2022

Source:- R.O.Water ( Girls Hostel )

## ISSUED TO:

 M/S Manav Rachna International Institute  
 of Research & Studies,  
 Sector-43, Suraj Kund Road,  
 Faridabad-121001 (Haryana)

Lab No.: 6102/W/2022

Your Ref.No.: NIL

SAMPLE DESCRIPTION: A Water Sample in a Pet Bottle.

### TEST RESULTS ( AS PER IS:10500-2012)

S.NO.PARAMETERS
RESULTS
IS:REQUIREMENTS

RELAXATION in absence

Desirable Limits of Alternate Source
PHYSICAL EXAMINATION

S.NO.	PARAMETERS	RESULTS	IS:REQUIREMENTS	RELAXATION in absence Desirable Limits of Alternate Source
1.	Colour	Unobjectionable	5 H.U. (Max.)	15
2.	Odour	Agreeable	Agreeable	Agreeable
3.	Taste	Agreeable	Agreeable	Agreeable
4.	Turbidity, NTU	NIL	1Max.	5
5.	pH	6.53	6.5-8.5	No Relaxation
6.	Dissolved Solids (mg/l)	105mg/l	500	2000

CHEMICAL EXAMINATION (mg/l)

1.	Total Alkalinity (as CaCO <sub>3</sub> )	27mg/l	200Max.	600
2.	Chlorides (as Cl)	51mg/l	250Max.	1000
3.	Total Hardness (as CaCO <sub>3</sub> )	62mg/l	200Max.	600
4.	Iron (as Fe)	*BDL	0.3Max.	No Relaxation
5.	Fluoride (as F)	*BDL	1.0Max.	1.5
6.	Residual Free Chlorine	*BDL	0.2Min.	1.0

\*B.D.L.:- Below detectable Limits.

Chemist/Microbiologist



Lab Incharge

## Note :

- The result listed refer only to tested parameters, Endorsement of product in neither inferred nor implied.
- Total Liabilities of our laboratory is limited to invoiced amount
- Sample will be destroyed after one month from the date of issue test certificate unless otherwise specified.
- This report is not to be reproduced wholly or in part & cannot be used in any advertising media or in any court without our special permission in writing.



**Indus Cosmeceuticals Pvt. Ltd.**

**Formerly FDRA Labs India Pvt. Ltd.**

ISO 9001 : 2008 (QMS) Certified  
Estd. Since 1976

Regd. Office : 819, Sector-7C, Faridabad.  
CIN : U74999HR1996PTC033021  
GSTIN No. 06AAACF2001M1Z3  
Office : HSIIDC No. 138-139,  
Sector-31, Faridabad-121 003 (India)  
Phone : 91-129-2278584, 2279087  
E-mail : fdralabs@incosmetics.org

Ref.No.:FDRA/21165/2022

Dated:19/12/2022

## TEST CERTIFICATE

Date & Time of Collection:- N.A.

Date of Receipt:17/12/2022

Collected by:- Sender

Date of Analysis:17/12/2022 to 19/12/2022

Source:- R.O.Water ( Girls Hostel )

### ISSUED TO:

M/S Manav Rachna International Institute  
of Research & Studies,  
Sector-43, Suraj Kund Road,  
Faridabad-121001 (Haryana)

Lab No.: 6102/W/2022  
Your Ref.No.: NIL

SAMPLE DESCRIPTION: A Water Sample in a Pet Bottle.

### BACTERIOLOGICAL EXAMINATION

#### MAX. ALLOWED AS PER

#### PARAMETERS

#### RESULTS W.H.O. Guidelines IS-10500:2012

Most Probable Number of Coliforms Organisms per 100ml. of Water.	(Absent)	3	Absent
---	----------	---	--------

OPINION:- The Bacteriological analysis of the sample indicates that it is ~~Fit / Unfit /~~  
~~Repeat Sampling Required~~ for Human Consumption.

Chemist/Microbiologist



Lab-Incharge



Ref.No.:FDRA/21125/2022

Dated:07/11/2022

### TEST CERTIFICATE

Date &amp; Time of Collection:- N.A.

Date of Receipt:04/11/2022

Collected by:- Sender

Date of Analysis:04/11/2022 to 07/11/2022

Source:- R.O.Water ( T- Block )

## ISSUED TO:

M/S Manav Rachna International Institute  
of Research & Studies,  
Sector-43, Suraj Kund Road,  
Faridabad-121001 (Haryana)

Lab No.: 6101/W/2022

Your Ref.No.: NIL


SAMPLE DESCRIPTION: A Water Sample in a Pet Bottle.

### TEST RESULTS ( AS PER IS:10500-2012)

<u>S.NO.PARAMETERS</u>	<u>RESULTS</u>	<u>IS:REQUIREMENTS</u> <u>RELAXATION in absence</u> <u>Desirable Limits of Alternate Source</u>	
<u>PHYSICAL EXAMINATION</u>			
1. Colour	Unobjectionable	5 H.U. (Max.)	15
2. Odour	Agreeable	Agreeable	Agreeable
3. Taste	Agreeable	Agreeable	Agreeable
4. Turbidity, NTU	NIL	1Max.	5
5. pH	6.52	6.5-8.5	No Relaxation
6. Dissolved Solids (mg/l)	332mg/l	500	2000
<u>CHEMICAL EXAMINATION (mg/l)</u>			
1. Total Alkalinity (as CaCO <sub>3</sub> )	43mg/l	200Max.	600
2. Chlorides (as Cl)	63mg/l	250Max.	1000
3. Total Hardness (as CaCO <sub>3</sub> )	125mg/l	200Max.	600
4. Iron (as Fe)	*BDL	0.3Max.	No Relaxation
5. Fluoride (as F)	*BDL	1.0Max.	1.5
6. Residual Free Chlorine	*BDL	0.2Min.	1.0

\*B.D.L.- Below detectable Limits.

Chemist/Microbiologist



Lab Incharge

## Note :

- The result listed refer only to tested parameters, Endorsement of product in neither inferred nor implied.
- Total Liabilities of our laboratory is limited to invoiced amount
- Sample will be destroyed after one month from the date of issue test certificate unless otherwise specified.
- This report is not to be reproduced wholly or in part & cannot be used in any advertising media or in any court without our special permission in writing.



JAS-ANZ



# Indus Cosmeceuticals Pvt. Ltd.

## Formerly FDRA Labs India Pvt. Ltd.

ISO 9001 : 2008 (QMS) Certified  
Estd. Since 1976

Regd. Office : 819, Sector-7C, Faridabad.  
CIN : U74999HR1996PTC033021  
GSTIN No. 06AAACF2001M1Z3  
Office : HSIIDC No. 138-139,  
Sector-31, Faridabad-121 003 (India)  
Phone : 91-129-2278584, 2279087  
E-mail : fdralabs@incosmetics.org

Ref.No.:FDRA/21125/2022

Dated:07/11/2022

### TEST CERTIFICATE

Date &amp; Time of Collection:- N.A.

Date of Receipt:04/11/2022

Collected by:- Sender

Date of Analysis:04/11/2022 to 07/11/2022

Source:- R.O.Water ( T- Block )

#### ISSUED TO:

M/S Manav Rachna International Institute  
of Research & Studies,  
Sector-43, Suraj Kund Road,  
Faridabad-121001 (Haryana)

Lab No.: 6101/W/2022

Your Ref.No.: NIL

SAMPLE DESCRIPTION: A Water Sample in a Pet Bottle.

### BACTERIOLOGICAL EXAMINATION

#### MAX. ALLOWED AS PER

<u>PARAMETERS</u>	<u>RESULTS</u>	<u>W.H.O. Guidelines</u>	<u>IS-10500:2012</u>
Most Probable Number of Coliforms Organisms per 100ml. of Water.	(Absent)	3	Absent

**OPINION:-** The Bacteriological analysis of the sample indicates that it is ~~Fit / Unfit /~~ Repeat Sampling Required for Human Consumption.

Chemist/Microbiologist



Lab-Incharge

- Note :
1. The result listed refer only to tested parameters, Endorsement of product is neither inferred nor implied.
  2. Total Liabilities of our laboratory is limited to invoiced amount
  3. Sample will be destroyed after one month from the date of issue test certificate unless otherwise specified.
  4. This report is not to be reproduced wholly or in part & cannot be used in any advertising media or in any court without our special permission in writing.

JMP DC- CBH-

JAS-ANZ



**Indus Cosmeceuticals Pvt. Ltd.**

**Formerly FDRA Labs India Pvt. Ltd.**

ISO 9001 : 2008 (QMS) Certified  
Estd. Since 1976

Regd. Office : 819, Sector-7C, Faridabad.  
CIN : U74999HR1996PTC033021  
GSTIN No. 06AAACF2001M1Z3  
Office : HSIIDC No. 138-139,  
Sector-31, Faridabad-121 003 (India)  
Phone : 91-129-2278584, 2279087  
E-mail : fdralabs@incosmetics.org

Ref.No.:FDRA/21017/2022

Dated:03/10/2022

**TEST CERTIFICATE**

Date & Time of Collection:- N.A.  
Collected by:- Sender  
Source:- R.O.Water

Date of Receipt:30/09/2022  
Date of Analysis:30/09/2022 to 03/10/2022

**ISSUED TO:**

M/S Manav Rachna Dental College,  
Sector-43, Suraj Kund Road,  
Faridabad-121001 (Haryana)

Lab No.: 6097/W/2022  
Your Ref.No.: NIL

SAMPLE DESCRIPTION: A Water Sample in a Pet Bottle.

**TEST RESULTS ( AS PER IS:10500-2012)**


<u>S.NO.PARAMETERS</u>	<u>RESULTS</u>	<u>IS:REQUIREMENTS</u> <u>RELAXATION in absence</u> <u>Desirable Limits of Alternate Source</u>	
<b>PHYSICAL EXAMINATION</b>			
1. Colour	Unobjectionable	5 H.U. (Max.)	15
2. Odour	Agreeable	Agreeable	Agreeable
3. Taste	Agreeable	Agreeable	Agreeable
4. Turbidity, NTU	NIL	1Max.	5
5. pH	6.52	6.5-8.5	No Relaxation
6. Dissolved Solids (mg/l)	79mg/l	500	2000

**CHEMICAL EXAMINATION (mg/l)**

1. Total Alkalinity (as CaCO <sub>3</sub> )	16mg/l	200Max.	600
2. Chlorides (as Cl)	33mg/l	250Max.	1000
3. Total Hardness (as CaCO <sub>3</sub> )	21mg/l	200Max.	600
4. Iron (as Fe)	*BDL	0.3Max.	No Relaxation
5. Fluoride (as F)	*BDL	1.0Max.	1.5
6. Residual Free Chlorine	*BDL	0.2Min.	1.0

\*B.D.L.:- Below detectable Limits.

Chemist/Microbiologist



**Note :**

- The result listed refer only to tested parameters, Endorsement of product in neither inferred nor implied.
- Total Liabilities of our laboratory is limited to invoiced amount
- Sample will be destroyed after one month from the date of issue test certificate unless otherwise specified.
- This report is not to be reproduced wholly or in part & cannot be used in any advertising media or in any court without our special permission in writing.

JAS-ANZ



# Indus Cosmeceuticals Pvt. Ltd.

## Formerly FDRA Labs India Pvt. Ltd.

ISO 9001 : 2008 (QMS) Certified  
Estd. Since 1976

Regd. Office : 819, Sector-7C, Faridabad.  
CIN : U74999HR1996PTC033021  
GSTIN No. 06AAACF2001M1Z3  
Office : HSIIDC No. 138-139,  
Sector-31, Faridabad-121 003 (India)  
Phone : 91-129-2278584, 2279087  
E-mail : fdralabs@incosmetics.org

Ref.No.:FDRA/21017/2022

Dated:03/10/2022

### TEST CERTIFICATE

Date & Time of Collection:- N.A.  
Collected by:- Sender  
Source:- R.O.Water

Date of Receipt:30/09/2022  
Date of Analysis:30/09/2022 to 03/10/2022

ISSUED TO:

M/S Manav Rachna Dental College,  
Sector-43, Suraj Kund Road,  
Faridabad-121001 (Haryana)

Lab No.: 6097/W/2022  
Your Ref.No.: NIL

SAMPLE DESCRIPTION: A Water Sample in a Pet Bottle.


### BACTERIOLOGICAL EXAMINATION

MAX. ALLOWED AS PER

<u>PARAMETERS</u>	<u>RESULTS</u>	<u>W.H.O. Guidelines</u>	<u>IS-10500:2012</u>
Most Probable Number of Coliforms Organisms per 100ml. of Water.	(Absent)	3	Absent

OPINION:- The Bacteriological analysis of the sample indicates that it is Fit / Unfit  
Repeat Sampling Required for Human Consumption.

Chemist/Microbiologist



- Note :
1. The result listed refer only to tested parameters, Endorsement of product in neither inferred nor implied.
  2. Total Liabilities of our laboratory is limited to Invoiced amount
  3. Sample will be destroyed after one month from the date of issue test certificate unless otherwise specified.
  4. This report is not to be reproduced wholly or in part & cannot be used in any advertising media or in any court without our special permission in writing.